



Product Service

# CERTIFICATE

No. Z2 109549 0001 Rev. 00

**Holder of Certificate:** **SOLYCO Solar AG**

Baseler Str. 60  
12205 Berlin  
GERMANY

**Certification Mark:**



**Product:**

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 701262012301-00

**Valid until:** 2025-08-25

**Date,** 2020-09-11

( Zhulin Zhang )



# CERTIFICATE

No. Z2 109549 0001 Rev. 00

**Model(s):** SOLON R-WF 120p/xxx (xxx=295-345 in step of 5);  
 SOLON R-BF 120p/xxx (xxx=295-345 in step of 5).  
 xxx is standing for rated output power at STC.

**Parameters:**

|                      |   |
|----------------------|---|
| Safety Class:        | Class II  |
| Max. System Voltage: | 1500V DC  |
| Test Laboratory:     | Yangzhou Opto-Electrical<br>Products Testing Institute<br>No. 10 West Kaifa Road, Yangzhou<br>225009 Jiangsu, P. R. China |
| Construction:        | Framed, with Junction box,<br>cable and connector.  |
| Fire Safety Class:   | Class C according to UL790  |

**Tested according to:**

IEC 61215-1:2016  
 EN 61215-1:2016  
 IEC 61215-1-1:2016  
 EN 61215-1-1:2016  
 IEC 61215-2:2016  
 EN 61215-2:2017  
 IEC 61730-1:2016  
 EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 IEC 61730-2:2016  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

**Production Facility(ies):**

077751